Kraus & Naimer

Datasheet

Sample image

A11C

Type Size: S2

Classification Contact: Rigid contact bridge

Classification Contact Mat: Silver

Classification Terminal: Screw terminal

IEC 60947-3 EN 60947-3, VDE 0660 Teil 107

Rated insulation voltage Ui

Voltage (V)	*AC / DC*
690	AC / DC

Rated impulse withstand voltage Uimp

Voltage (kV)	*Overvoltage category*	*Pollution degree*	*Supply system*	*Function*
6	III	3	Valid for lines with grounded common neutral termination	Switch

Rated uninterrupted current Iu/Ith

Current (A)	*Ambient temperature (°C)*	*Peak temperature (°C)*	*additional requirements*
20	55	60	Ambient temperature +55°C during 24 hours with peaks up to +60°C

Conventional enclosed thermal current Ithe

Current (A)	*Ambient temperature (°C)*	*Peak temperature (°C)*	*Additional requirements*	*No. of stages (from - to)*	*Mounting*	*Mounting size*
20	35	40	Ambient temperature +35°C during 24 hours with peaks up to +40°C	--	--	--

Rated operational current Ie

Utilization category	*Voltage (V)*	*Current (A)*
AC-15	220 - 240	6
AC-15	380 - 440	4
AC-20A	690	20
AC-21A	20 - 690	20
AC-22A	220 - 500	20
AC-22A	660 - 690	16

Rated operational power

Utilization category	*Voltage (V)*	*No. of phases*	*No. of poles*	*Power (kW)*
AC-2	220 - 240	3	3	4
AC-2	380 - 440	3	3	7,50
AC-2	500 - 500	3	3	10
AC-2	660 - 690	3	3	10
AC-3	220 - 240	3	3	3
AC-3	380 - 440	3	3	5,50
AC-3	500 - 500	3	3	5,50
AC-3	660 - 690	3	3	5,50
AC-3	110 - 110	1	2	0,60
AC-3	220 - 240	1	2	2,20
AC-3	380 - 440	1	2	3
AC-4	220 - 240	3	3	0,55
AC-4	380 - 440	3	3	1,50
AC-4	500 - 500	3	3	1,50
AC-4	660 - 690	3	3	1,50
AC-4	110 - 110	1	2	0,15
AC-4	220 - 240	1	2	0,25
AC-4	380 - 440	1	2	0,55
AC-23A	220 - 240	3	3	3,70
AC-23A	380 - 440	3	3	7,50
AC-23A	500 - 500	3	3	7,50
AC-23A	660 - 690	3	3	7,50
AC-23A	110 - 110	1	2	0,75
AC-23A	220 - 240	1	2	2,20

Rated operational power				
Utilization category	*Voltage (V)*	*No. of phases*	*No. of poles*	*Power (kW)*
AC-23A	380 - 440	1	2	3,70

Max. Fuse rating IEC		
Fuse characteristic	*No. of Fuses*	*Current (A)*
gG	1	20

UL60947-4-1 , UL508

Rated insulation voltage Ui		
	Voltage (V)	*AC / DC*
	600	AC

Rated thermal current			
Current (A)	*Ambient temperature (°C)*	*Additional Text*	
10	0 - 40	--	

GENERAL TECHNICAL INFORMATION

Tightening torque of screws		
	tightening torque (Nm)	*tightening torque (lb-in)*
	0,60	5

Rated short-time withstand current Icw		
	Time (s)	*Current (A)*
	1	120

Size of conductor				
composition of conductor	*Min. / Max. value*	*No. of conductor per terminal*	*Cross section (mm²) or (AWG/kcmil)*	*Material of the wire*
Flexible wire	Max.	1	2.5mm²	Copper
Flexible wire	Max.	1	AWG 14	Copper
Single-core or stranded wire	Max.	1	AWG 12	Copper
Single-core or stranded wire	Max.	1	2.5mm²	Copper
Flexible wire with ferrule according to DIN 46228	Max.	1	2.5mm²	Copper

Approbations	
Specification	*Marking*
CE marking	CE
UK Directives	
IEC 60947-3; EN 60947-3; VDE 0660 Teil107	IEC 60947-3 EN 60947-3
UL 60947-4-1; CSA C22.2 No. 60947-4-1	c UL us LISTED 77B7
CSA C.22.2 No.14	SP®

Power loss per pole	
	Power (W)
	0,90

Conditions during transport and storing		
Minimum temperature (°C)	*Maximum temperature (°C)*	*additional requirements*
-40	85	In case of temperatures below -5°C no shock load permissible

Shock / Vibration	
Type of oscillation	*Values*
Resistance to vibration	IEC 61373 (2010) Category 1, Class B

General Information

Text

- Use only copper wires with or without tinned/silver-plated individual wires. Soldering the end of the wire before wiring is not allowed.
- Terminals with factory fitted jumper links are tightened during production for loss prevention. When opening the terminal clamps, make sure that no factory fitted links get lost and that all wire connections are properly seated.
- After wiring, ALL terminal screws must be tightened to the specified torque values.
- The protection class of the selected mounting type may vary if optional extras are used.
- Do not lubricate or treat contacts.
- Switches may only be mounted, connected and set into operation by qualified persons according to the accepted rules of technology.
- Use only fully insulated cable lugs resp. FASTON receptacles.
- After installation of the switches the spacings between the terminals must be sufficient to fulfill the requirement of the applicable standards.

Operating temperature	
Min. Temperature [°C]	*Max. Temperature [°C]*
-25	60